

**CITY OF MARTINSVILLE
DEMOLITION OF STANDPIPE SPECIFICATIONS
BETHEL LANE WATER STORAGE FACILITY**

ADDENDUM No. 1

March 29, 2016

1. The Sign-In Sheet and minutes of the Pre-Bid Meeting held March 29, 2016 are included.

End of Addendum No. 1



**CITY OF MARTINSVILLE
DEMOLITION OF STANDPIPE SPECIFICATIONS
BETHEL LANE WATER STORAGE FACILITY**

PRE-BID MEETING

MARCH 29, 2016

1. Sign-In Sheet - attached
2. Bid Date: **Thursday April 7, 2016 at 2:00 p.m.** at Fishel Street Warehouse, 990 Fishel Street.
3. Bid Bond: A bid bond equal to 5% of the contractor's bid is required.
4. Performance Bond: A bond equal to 100% of the contractor's bid is required, if successful.
5. All construction is scheduled to be completed within 60 days of Notice to Proceed.
6. Traffic and flagging control are the responsibility of the Contractor.
7. Work includes: Demolition and removal of a 25' by 75', iron plate, water storage tank, capping of underground piping, and restoration of disturbed areas.
8. All questions or comments shall be sent to Karen Mays via email for distribution. An addendum will be issued for this project following today's meeting.
9. Chris Morris, City Engineer/ Assistant Public Works Director, is the designated contact person. (276) 403-5159.
10. Mike Kahle, Project Manager, is the designated inspector. (276) 806-0250.
11. Working hours will consist of daylight hours, approximately 7:00 a.m. to 8:00 p.m.
12. The existing concrete foundation is to remain.
13. The City will issue a press release in conjunction with the start of demolition work.
14. Partial street closure of Bethel Lane will be permitted. Flagmen shall be used to allow residents ingress/egress to their properties during road closures.
15. Prevailing wages are not applicable to this project.
16. The water main piping shall be flush with the foundation and capped using concrete.
17. Questions:
 - Can the fence be removed? – **Yes, the fence can be removed if reinstalled.**
 - Can the overhead wires inside the fencing, near the pump house be removed? – **Yes, the City will remove these low hanging wires.**
 - Can stone base be added for equipment stability? – **Yes, stone can be brought in as long as access to all valve boxes remains. Excess stone shall be removed.**

